

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Outfall No. 702	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.3587	x	231	x	8.34	=	691
February	0.3699	x	221	x	8.34	=	683
March	0.3787	x	200	x	8.34	=	631
April	0.3560	x	230	x	8.34	=	681
May	0.3133	x	221	x	8.34	=	577
June	0.2817	x	216	x	8.34	=	507
July	0.2593	x	226	x	8.34	=	488
August	0.2951	x	211	x	8.34	=	520
September	0.3126	x	193	x	8.34	=	504
October	0.3056	x	215	x	8.34	=	549
November	0.2984	x	221	x	8.34	=	550
December	0.3059	x	250	x	8.34	=	639

2. Maximum Monthly Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.62	x	90	=	0.558
		x	100	=	.62
Design (C)BOD, lbs/day	1600	x	90	=	1440
		x	100	=	1600

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?
 Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

Influent flow is not metered. Effluent flow meter only.

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

18,000 gallons (1500 gallons per month) of slaughter house waste. Waste was pumped directly to the digester.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	14	1	0	0
February	30	27	10	1	0	0
March	30	27	6	1	0	0
April	30	27	5	1	0	0
May	30	27	13	1	0	0
June	30	27	12	1	0	0
July	30	27	10	1	0	0
August	30	27	11	1	0	0
September	30	27	12	1	0	0
October	30	27	14	1	0	0
November	30	27	11	1	0	0
December	30	27	11	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- Yes Enter last calibration date (MM/DD/YYYY)

- No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

- Yes

- No

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

<p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	10	1	0	0
February	30	27	7	1	0	0
March	30	27	4	1	0	0
April	30	27	3	1	0	0
May	30	27	11	1	0	0
June	30	27	10	1	0	0
July	30	27	11	1	0	0
August	30	27	14	1	0	0
September	30	27	11	1	0	0
October	30	27	13	1	0	0
November	30	27	11	1	0	0
December	30	27	9	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				12		
Points per each exceedance with 12 months of discharge:					7	3
Exceedances					0	0
Points					0	0
Total Number of Points						0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January									
February									
March									
April									
May	5.2		.072307692	0					
June	5.2		.212857143	0					
July	5.2		.166666667	0					
August	5.2		.172666667	0					
September	5.2		.315833333	0					
October									
November									
December									
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.5	1	0
February	1	0.5	1	0
March	1	0.4	1	0
April	1	0.5	1	0
May	1	0.7	1	0
June	1	0.5	1	0
July	1	0.5	1	0
August	1	0.6	1	0
September	1	0.6	1	0
October	1	0.7	1	0
November	1	0.6	1	0
December	1	0.5	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

1522 acres

2.1.2 How many acres did you use?

22 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

Yes (30 points)

No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

Yes

No (10 points)

N/A

0

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75										<5.2				0	0
Cadmium		39	85										.65				0	0
Copper		1500	4300										319				0	0
Lead		300	840										22.6				0	0
Mercury		17	57										1.1				0	0
Molybdenum	60		75										30.4			0		0
Nickel	336		420										41.1			0		0
Selenium	80		100										13.7			0		0
Zinc		2800	7500										708				0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

0 (0 Points)

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

<p> <input type="radio"/> 1-2 (10 Points) <input type="radio"/> > 2 (15 Points) 3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box) <input type="radio"/> Yes <input type="radio"/> No (10 points) <input checked="" type="radio"/> N/A - Did not exceed limits or no HQ limit applies (0 points) <input type="radio"/> N/A - Did not land apply biosolids until limit was met (0 points) 3.1.3 Number of times any of the metals exceeded the ceiling limits = 0 Exceedence Points <input checked="" type="radio"/> 0 (0 Points) <input type="radio"/> 1 (10 Points) <input type="radio"/> > 1 (15 Points) 3.1.4 Were biosolids land applied which exceeded the ceiling limit? <input type="radio"/> Yes (20 Points) <input checked="" type="radio"/> No (0 Points) 3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified? <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div> </p>	0																				
<p>4. Pathogen Control (per outfall):</p> <p>4.1 Verify the following information. If any information is incorrect, use the Report Issue button under the Options header in the left-side menu.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 40%;">Outfall Number:</td> <td>002</td> </tr> <tr> <td>Biosolids Class:</td> <td>B</td> </tr> <tr> <td>Bacteria Type and Limit:</td> <td></td> </tr> <tr> <td>Sample Dates:</td> <td>01/01/2016 - 12/31/2016</td> </tr> <tr> <td>Density:</td> <td>0</td> </tr> <tr> <td>Sample Concentration Amount:</td> <td></td> </tr> <tr> <td>Requirement Met:</td> <td>Yes</td> </tr> <tr> <td>Land Applied:</td> <td>Yes</td> </tr> <tr> <td>Process:</td> <td>Aerobic Digestion</td> </tr> <tr> <td>Process Description:</td> <td>Digester Maintained at 96 degrees F.</td> </tr> </table> <p>4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.</p> <p>4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?</p> <p> <input type="radio"/> Yes (40 Points) <input checked="" type="radio"/> No If yes, what action was taken? <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div> </p>	Outfall Number:	002	Biosolids Class:	B	Bacteria Type and Limit:		Sample Dates:	01/01/2016 - 12/31/2016	Density:	0	Sample Concentration Amount:		Requirement Met:	Yes	Land Applied:	Yes	Process:	Aerobic Digestion	Process Description:	Digester Maintained at 96 degrees F.	0
Outfall Number:	002																				
Biosolids Class:	B																				
Bacteria Type and Limit:																					
Sample Dates:	01/01/2016 - 12/31/2016																				
Density:	0																				
Sample Concentration Amount:																					
Requirement Met:	Yes																				
Land Applied:	Yes																				
Process:	Aerobic Digestion																				
Process Description:	Digester Maintained at 96 degrees F.																				
<p>5. Vector Attraction Reduction (per outfall):</p> <p>5.1 Verify the following information. If any of the information is incorrect, use the Report Issue button under the Options header in the left-side menu.</p>																					

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Outfall Number:	002	0
Method Date:	11/09/2016	
Option Used To Satisfy Requirement:	Volatile Solids Reduction	
Requirement Met:	Yes	
Land Applied:	Yes	
Limit (if applicable):	> = 38	
Results (if applicable):	56.30	
<p>5.2 Was the limit exceeded or the process criteria not met at the time of land application?</p> <p><input type="radio"/> Yes (40 Points)</p> <p><input checked="" type="radio"/> No</p> <p>If yes, what action was taken?</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>		
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <p><input checked="" type="radio"/> >= 180 days (0 Points)</p> <p><input type="radio"/> 150 - 179 days (10 Points)</p> <p><input type="radio"/> 120 - 149 days (20 Points)</p> <p><input type="radio"/> 90 - 119 days (30 Points)</p> <p><input type="radio"/> < 90 days (40 Points)</p> <p><input type="radio"/> N/A (0 Points)</p> <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>		
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; padding: 2px;">None</div>		

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes (Continue with question 2)<input type="radio"/> No (40 points) <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<ul style="list-style-type: none"><input type="radio"/> Paper file system<input type="radio"/> Computer system<input checked="" type="radio"/> Both paper and computer system<input type="radio"/> No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><input type="radio"/> Excellent<input type="radio"/> Very good<input checked="" type="radio"/> Good<input type="radio"/> Fair<input type="radio"/> Poor <p>Describe your rating:</p>	

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Aging equipment for wastewater processes requires more maintenance. Upgrades to process equipment is being done.	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p> <p>Name: <input style="width: 300px;" type="text" value="DANIEL G MARKART"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="24630"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Basic</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td></td><td></td><td></td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td></td><td></td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>P</td><td>Total Phosphorus</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>L</td><td>Laboratory</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td>X</td><td>NA</td><td>NA</td><td>NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2016; subclass SS is basic level only.)</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p>	Sub Class	SubClass Description	WWTP		OIC		Basic	OIT	Basic	Advanced	A1	Suspended Growth Processes					A2	Attached Growth Processes	X			X	A3	Recirculating Media Filters					A4	Ponds, Lagoons and Natural					A5	Anaerobic Treatment Of Liquid					B	Solids Separation	X			X	C	Biological Solids/Sludges	X			X	P	Total Phosphorus	X			X	N	Total Nitrogen					D	Disinfection	X			X	L	Laboratory	X			X	U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	NA	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Basic	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes																																																																																								
A2	Attached Growth Processes	X			X																																																																																				
A3	Recirculating Media Filters																																																																																								
A4	Ponds, Lagoons and Natural																																																																																								
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation	X			X																																																																																				
C	Biological Solids/Sludges	X			X																																																																																				
P	Total Phosphorus	X			X																																																																																				
N	Total Nitrogen																																																																																								
D	Disinfection	X			X																																																																																				
L	Laboratory	X			X																																																																																				
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	NA	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <p><input checked="" type="checkbox"/> One or more additional certified operators on staff</p> <p><input type="checkbox"/> An arrangement with another certified operator</p> <p><input type="checkbox"/> An arrangement with another community with a certified operator</p> <p><input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year</p> <p><input type="checkbox"/> A consultant to serve as your certified operator</p> <p><input type="checkbox"/> None of the above (20 points)</p> <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div>	0																																																																																								
<p>4. Continuing Education Credits</p>																																																																																									

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

OIT and Basic Certification:

- Averaging 6 or more CECs per year.
- Averaging less than 6 CECs per year.

Advanced Certification:

- Averaging 8 or more CECs per year.
- Averaging less than 8 CECs per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 300px;" type="text" value="Jennifer Sweeney"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="608-592-0716"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="jsweeney@wppienergy.org"/></p>													
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2016"/></p> <p><input checked="" type="radio"/> 0-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFPP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p>	0												
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>													
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 150px;" type="text" value="2016"/></p> <p><input checked="" type="radio"/> 1-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>													
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%; text-align: center;">\$</td> <td style="width: 35%; text-align: right;"><input style="width: 150px;" type="text" value="675,574.17"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: center;">-</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: center;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="675,574.17"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="23,134.14"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 150px;" type="text" value="675,574.17"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	-	<input style="width: 150px;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 150px;" type="text" value="675,574.17"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	<input style="width: 150px;" type="text" value="23,134.14"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 150px;" type="text" value="675,574.17"/>											
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	-	<input style="width: 150px;" type="text" value="0.00"/>											
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 150px;" type="text" value="675,574.17"/>											
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	<input style="width: 150px;" type="text" value="23,134.14"/>											

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) -

\$ 4,337.19

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 694,371.12

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

Adjust to actual for Jan, Feb, Mar 2016 estimate for depreciation, bond payment, PILOT, utility rent.

3.3 What amount should be in your Replacement Fund?

\$ 694,371.12

0

Please note: If you had a CWWP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	The City of Lodi is pursuing Adaptive Management for phosphorus compliance. The WPDES permit requires the City to comply with a water quality based effluent limit of 0.075 mg/L (annual average) and a 0.22 mg/L (monthly average) for total phosphorus by 2020. Reaching this goal using traditional facility upgrades would be cost-prohibitive. Therefore, alternative watershed-based compliance options, specifically Adaptive Management, are being pursued.	4200000	2020

5. Financial Management General Comments

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	1,385	
February	1,305	
March	1,402	
April	1,325	
May	1,454	
June	1,318	
July	1,118	
August	875	
September	917	
October	994	
November	976	
December	1,005	
Total	14,074	0
Average	1,173	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

None.

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	35,900	11.12	3,228	21.42	1,676	1,759
February	31,800	10.73	2,964	19.81	1,605	1,539
March	31,300	11.74	2,666	19.56	1,600	1,255
April	29,000	10.68	2,715	20.43	1,419	1,353
May	29,700	9.71	3,059	17.89	1,660	390
June	28,800	8.45	3,408	15.21	1,893	340
July	28,200	8.04	3,507	15.13	1,864	217
August	28,600	9.15	3,126	16.12	1,774	202
September	27,600	9.38	2,942	15.12	1,825	308
October	30,700	9.47	3,242	17.02	1,804	386
November	31,100	8.95	3,475	16.50	1,885	764
December	32,300	9.48	3,407	19.81	1,630	1,536
Total	365,000	116.90		214.02		10,049
Average	30,417	9.74	3,145	17.84	1,720	837

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

Upgrade boiler and pump rebuilds.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

2009

By Whom:

Science Applications International Corporation (SAIC) through Focus on Energy

Describe and Comment:

This energy study identified and evaluated energy efficiency opportunities. The study includes details and projected savings for each measure.

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Cleaning of 25% of collection system annually. Establish a FOG program. Televisive collection system and locate private laterals.

Did you accomplish them?

- Yes
- No

If No, explain:

Aging plant process equipment and adaptive management require additional staff hours.

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Sewer Use Ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2006-06-30

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance
- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
 A description of routine operation and maintenance activities (see question 2 below)
 Capacity assessment program
 Basement back assessment and correction
 Regular O&M training
 Design and Performance Provisions [NR 210.23 (4) (e)]
 What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?
 State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
 Construction, Inspection, and Testing
 Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]
 Does your emergency response capability include:
 Responsible personnel communication procedures
 Response order, timing and clean-up
 Public notification protocols
 Training
 Emergency operation protocols and implementation procedures
 Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]
 Special Studies Last Year (check only those that apply):
 Infiltration/Inflow (I/I) Analysis
 Sewer System Evaluation Survey (SSES)
 Sewer Evaluation and Capacity Management Plan (SECAP)
 Lift Station Evaluation Report
 Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="23"/>	% of system/year
Root removal	<input type="text" value="2"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="5"/>	% of system/year
Manhole inspections	<input type="text" value="23"/>	% of system/year
Lift station O&M	<input type="text" value="12"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="5"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Private sewer I/I removal % of private services

River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="47.76"/>	Total actual amount of precipitation last year in inches
<input type="text" value="36"/>	Annual average precipitation (for your location)
<input type="text" value="17"/>	Miles of sanitary sewer
<input type="text" value="2"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="1"/>	Number of basement backup occurrences
<input type="text" value="0"/>	Number of complaints
<input type="text"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.06"/>	Basement backups (number/sewer mile)
<input type="text" value="0.00"/>	Complaints (number/sewer mile)
<input type="text"/>	Peaking factor ratio (Peak Monthly: Annual Daily Avg)
<input type="text"/>	Peaking factor ratio (Peak Hourly: Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **			
Date	Location	Cause	Estimated Volume (MG)
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

<ul style="list-style-type: none">● No <p>If Yes, please describe:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:
<div style="border: 1px solid black; padding: 2px;">None.</div>
5.4 What is being done to address infiltration/inflow in your collection system?
<div style="border: 1px solid black; padding: 2px;">I/I areas in collection system are identified and eliminated as the existing sanitary sewer mains are replaced with new mains.</div>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Grading Summary

WPDES No: 0022918

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	148
GRADE POINT AVERAGE (GPA) = 4.00				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

Lodi Wastewater Treatment Facility

Last Updated: Reporting For:
6/22/2017 2016

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Lodi Utilities Commission

Date of Resolution or
Action Taken:

2017-06-21

Resolution Number:

UC 17-03

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR
SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL
GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 4.00